

January 31, 2011

President & Board of Directors
Harris County Municipal Utility District No. 1
c/o Smith Murdaugh Little & Bonham
1100 Louisiana, Suite 400
Houston, TX 77002

Re: Drainage Projects within Harris County MUD No. 1
VEI File No. 19900-202-1-DCH (p)

Dear Sirs:

Localized flooding within the Wimbledon Country Section 1 subdivision has been documented. Van De Wiele & Vogler, Inc. was engaged as Harris County MUD No. 1's District Engineer on May 14, 2002. Since that time, Harris County Municipal Utility District No. 1 has authorized the following drainage projects that have been completed and reduced stormwater discharge to the existing Wimbledon Country Section 1 drainage system:

- diversion of portions of the northwest off-site drainage area through the Wimbledon Falls drainage system as part of Wimbledon Falls Section 1 and 2 development.
- berm improvements that raised the height and improved the integrity of the berm protecting the subdivision from off-site drainage areas to the west.
- A relief storm sewer pipe and extension of the Harris County Flood Control District's M109-02-00 drainage channel is now substantially complete.

These improvements have been hydraulically modeled and the model indicates that no home slabs within Wimbledon Country Section 1 will be inundated during a 100 year design storm event.

I hope that this information is helpful.

Sincerely,

VAN DE WIELE & VOGLER, INC.
District Engineer – Harris County M.U.D. No. 1



Erik Spencer, P.E.
Senior Project Manager